

1. OGGETTO DEL TEST REPORT / ITEM UNDER TEST REPORT

Descrizione <i>Description</i>	Radiator
Modello <i>Model type</i>	ULISSE
Identificativo interno <i>Storage No.</i>	200485/2 (Sampled by applicant)
Richiedente <i>Applicant</i>	Caleido S.r.l.
Indirizzo <i>Address</i>	Via Pablo Neruda, 52/A – 25020 Flero (BS) - ITALY

Prove effettuate presso <i>Test carried out by</i>	TÜV Rheinland Italia Srl Via E. Mattei, 3 – 20010 Pogliano Milanese (Italy)
Norme di riferimento <i>Reference Standards</i>	EN 61000-3-2:2019; EN 61000-3-3:2013 + A1:2019 EN 55014-1:2017; EN 55014-2:2015
Scopo delle prove <i>Scope of the tests</i>	To verify the compliance with the following clauses of reference standards See part 10. TESTS SUMMARY section
Risultati di prova <i>Test Results</i>	COMPLIANT

Data ricevimento campioni <i>Date of samples receiving</i>	13/07/2020		
Data inizio prove <i>Date of tests start</i>	14/07/2020	Data fine prove <i>Date of tests end</i>	15/07/2020
Rapporto composto da <i>Test report composed by</i>	36 Pages		

Provato da / Tested by
(name + signature)

Approvato da / Approved by
(name + signature)

Roberto Radice
(Laboratory Technician)

Andrea Bortolotti
(Reviewer)

The results referred in this report are only relevant to the samples tested and described in this report.
Only complete reproduction of this test report is permitted without written authorisation of TÜV Rheinland Italia
TRI refuses any responsibility about information supplied by the customer contained in this test report
TÜV Rheinland Italia – Via Enrico Mattei, 3 – 20010 Pogliano Milanese (MI) – Italy Tel. +39 02 9396871 Fax. +39 02 93968723

RELEASE CONTROL RECORD

TEST REPORT NUMBER	REASON OF CHANGE	DATE OF ISSUE
28119842 004	Original release	07/08/2020

2. OGGETTO SOTTOPOSTO A PROVE / ITEM UNDER TEST

Descrizione

Description

Radiator

Marca

Brand

Costruttore

Manufacturer

Modello

Model / Type reference

Dati di targa

Ratings

Classificazione

EUT classification

Category II

Massima frequenza di clock

Maximum clock frequency

<15MHz

Installazione

Standing

Wall



3. MODELLI DERIVATI / DERIVED MODELS

Model	Differences
None	

4. LISTA COMPONENTI / COMPONENTS LIST

Description	Manufacturer	Model Name	Technical data
Electronic module	SELMO srl	MUSA PLUS W-CL1-S	230V 50/60Hz SW Rev. 4.41

5. COMPONENTI AUSILIARI / ANCILLARY EQUIPMENTS

Description	Manufacturer	Model name
None		

6. SOFTWARE E VERSIONE DEI FIRMWARE / SOFTWARE AND FIRMWARE VERSIONS

Description	Manufacturer	Model name
/		

7. PORTE DI INTERFACCIA / INTERFACE PORTS

Port	Description	Connections	
		(Un)Shielded	Length
Enclosure	Radiator: conductive surface Electronic module: non conductive surface	Closed by screws	---
AC Mains	Input 230Vac 50/60Hz (Phase-Neutral with protective earth)	No	---
DC Port	Port not present		
Signals	Port not present		

8. MODALITA' DI FUNZIONAMENTO / OPERATING MODES

Operation mode		Description	Representative parameter
#1	Working mode	Heating element on (setting temperature 30°C)	Heating element On Display of electronic module
#2	Working mode	Flicker: 1 manual start and 1 manual stop	/

9. CRITERI DI VALUTAZIONE PER I TEST DI IMMUNITA' / COMPLIANCE CRITERIA FOR IMMUNITY TESTS

Performance criterion A:

The apparatus shall continue to operate as intended during and after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended. The performance level may be replaced by a permissible loss of performance. If the minimum performance level or the permissible performance loss is not specified by the manufacturer, either of these may be derived from the product description and documentation and what the user may reasonably expect from the apparatus if used as intended.

Performance criterion B:

The apparatus shall continue to operate as intended after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended. The performance level may be replaced by a permissible loss of performance. During the test, degradation of performance is however allowed. No change of actual operating state or stored data is allowed. If the minimum performance level or the permissible performance loss is not specified by the manufacturer, either of these may be derived from the product description and documentation and what the user may reasonably expect from the apparatus if used as intended.

Performance criterion C:

Temporary loss of function is allowed, provided the function is self-recoverable or can be restored by the operation of the controls.

Representative parameter	Acceptable level of performance	Observation mode		
		Acquisition	Test equipment	Test n.
Heating element On	According to performance criteria of Standard EN 55014-2	By visualization	Operator	All immunity tests
Display of electronic module	According to performance criteria of Standard EN 55014-2	By visualization	Operator	All immunity tests

Reference Document		Title of Document
EN 55014-1	2017	Electromagnetic compatibility - Requirements for household appliances, electric tools and similar apparatus Part 1: Emission
EN 55014-2	2015	Electromagnetic compatibility - Requirements for household appliances, electric tools and similar apparatus Part 2: Immunity - Product family standard
EN 61000-3-2	2019	Electromagnetic compatibility (EMC) Part 3-2: Limits - Limits for harmonic current emissions (equipment input current ≤ 16 A per phase)" is an international standard concerning the harmonics emitted by electric equipment.
EN 61000-3-3 A1	2013 2019	Electromagnetic compatibility (EMC) Part 3-3: Limits - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection
EN/IEC 61000-4-2	2009*	Electromagnetic compatibility (EMC) Part 4-2: Testing and measurement techniques – Electrostatic discharge immunity test
EN/IEC 61000-4-3 A1 A2 IS1	2006* 2008 2010 2009	Electromagnetic compatibility (EMC) Part 4-3: Testing and measurement techniques – Radiated, radiofrequency, electromagnetic field immunity test
EN/IEC 61000-4-4	2012*	Electromagnetic compatibility (EMC) Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test
EN/IEC 61000-4-5	2006*	Electromagnetic compatibility (EMC) Part 4-5: Testing and measurement techniques – Surge immunity test
EN/IEC 61000-4-6	2009*	Electromagnetic compatibility (EMC) Part 4-6: Testing and measurement techniques – Immunity to conducted disturbances, induced by radio-frequency fields
EN/IEC 61000-4-11	2006*	Electromagnetic compatibility (EMC) Part 4-11: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests

* For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

10. SOMMARIO DELLE PROVE / TESTS SUMMARY

HARMONIC CURRENTS – ARMONICHE DI CORRENTE	15
FLICKER – FLUTTUAZIONI DI TENSIONE	19
CONDUCTED EMISSION – EMISSIONE CONDOTTA	21
POWER DISTURBANCE – POTENZA DI DISTURBO	24
ELECTROSTATIC DISCHARGE – SCARICHE ELETTROSTATICHE	26
FAST TRANSIENTS - TRANSITORI VELOCI	29
SURGE - IMPULSI.....	31
INJECTED CURRENTS - CORRENTI INIETTATE	33
VOLTAGE DIPS – BUCHI DI TENSIONE.....	35

DECISION RULE

Statements of conformity (PASS or FAIL) to specifications are made in this report without taking measurement uncertainty into account.

Where statements of conformity are made in this report, the following decision rules are applied:

PASS – Results within limits/specifications

FAIL – Results exceed limits/specifications

(emission test according to CISPR 16-4-2 cl.4.2, immunity tests TRI applies the disturbance level indicated in the product standard)

11. ESITO DELLE PROVE DI EMISSIONE / EMISSION TESTS RESULT

Prova / Test	Porta / Port	Esito / Result
Emissione condotta / <i>Continuous disturbance voltage</i>	AC mains	PASS
Emissione radiata / <i>Radiated disturbance</i>	Enclosure	N.E. ¹
Armoniche di corrente / <i>Harmonic current emissions</i>	AC mains	PASS
Flicker e oscillazioni di tensione / <i>Voltage fluctuations and flicker</i>	AC mains	PASS
Click / <i>Click</i>	AC mains	N.A. ²
Potenza Radiata / <i>Disturbance power</i>	AC mains	PASS

N.E.¹ the Laboratory has executed Disturbance power test in Range 30-300MHz; clock frequency <15MHz
N.A.² According to par. 5.4.3.2 Individual switching operations of Standard EN 55014-1: any disturbance caused by individual switching operations shall be disregarded for the purpose of testing the EUT for compliance with the limits of radio disturbance set out in this standard. (Example: the changing of the manual setting of a continuously adjustable control such as a variable speed device for water extraction or electronic thermostats).

Legend:

Pass = Result within the limits

N/A = Not Applicable

N/R = Not requested by the Client

12. ESITO DELLE PROVE DI IMMUNITA' / IMMUNITY TESTS RESULT

Prova / Test	Porta / Port	Esito / Result
Scariche Elettrostatiche / Electrostatic discharges	Enclosure	PASS
Immunità radiata / Radiated electromagnetic field	Enclosure	N.A.
Transitori veloci di tensione / Electrical Fast Transients	AC power	PASS
Impulsi / Surge	AC mains	PASS
Immunità condotta / Injected currents	AC power	PASS
Buchi e interruzioni brevi di tensione / Dips and Short interruptions	AC mains	PASS

Legend:


Pass = Result within the limits

N/A = Not Applicable

N/R = Not requested by the Client

13. DOCUMENTAZIONE FOTOGRAFICA / PHOTOGRAPHIC DOCUMENTATION







Conducted emission on AC input test set-up



Conducted emission on AC input test set-up




Power disturbance test set-up



Power disturbance test set-up



Conducted immunity on AC input test set-up



Conducted immunity on AC input test set-up



Burst/surge on AC input test set-up



Burst/surge on AC input test set-up



ESD test set-up



ESD test set-up



Harmonics, Flicker and voltage dips test set-up



Harmonics, Flicker and voltage dips test set-up

Test N.1

HARMONIC CURRENTS – ARMONICHE DI CORRENTE

Reference Standard

EN 61000-3-2

List of reference equipment

- Stabilized Power Supply Ametek mod. MX30 (Inv. 2781967)
- Harmonics Analyzer EM Test mod. DPA503 (Inv. 2781969)
- Software EM Test NET.control 2.1.5

Measurement Uncertainty

Expanded uncertainty: 4,1% of reading
Coverage probability: 95 %
Coverage factor: 2,0

Number of samples under test

1

Test Conditions

Required

Measured

Ambient Temperature

(15 ÷ 35) °C

(22 ± 2) °C

Ambient Relative Humidity

(25 ÷ 75) %rH

(55 ± 10) %rH

Test Setup

EN 61000-3-2 Annex A

Test Procedure

EN 61000-3-2 par. 6.2

EUT Operating Mode(s)

#1

Acceptance Criteria

Limits are indicated in EN 61000-3-2, Class A

Measured values			
<i>Fundamental Current</i>			
Line 1:	6,154 A		
<i>Active input Power</i>			
Line 1:	1411 W		
<i>Circuit power factor</i>			
Line 1:	1,00		
Standard used:	EN/IEC 61000-3-2 Ed.3 Short cyclic Equipment class A <= 150% of the limit		
Observation time:	60s		

Average harmonic current results

Hn	I _{eff} [A]	% of Limit	Limit [A]	Result
1	6.116			
2	1.689E-3			PASS
3	4.373E-3			PASS
4	1.956E-3			PASS
5	4.150E-3			PASS
6	2.268E-3			PASS
7	2.988E-3			PASS
8	2.027E-3			PASS
9	4.054E-3			PASS
10	1.843E-3			PASS
11	3.369E-3			PASS
12	1.849E-3			PASS
13	1.931E-3			PASS
14	1.777E-3			PASS
15	2.753E-3			PASS
16	1.811E-3			PASS
17	2.017E-3			PASS
18	1.750E-3			PASS
19	1.967E-3			PASS
20	1.650E-3			PASS
21	2.241E-3			PASS
22	1.609E-3			PASS
23	1.924E-3			PASS
24	1.710E-3			PASS
25	2.045E-3			PASS
26	2.017E-3			PASS
27	2.331E-3			PASS
28	1.881E-3			PASS
29	2.239E-3			PASS
30	1.804E-3			PASS
31	1.745E-3			PASS
32	1.629E-3			PASS
33	2.093E-3			PASS
34	1.650E-3			PASS
35	2.058E-3			PASS
36	1.734E-3			PASS
37	2.487E-3			PASS
38	2.154E-3			PASS
39	2.597E-3			PASS
40	1.956E-3			PASS

Maximum harmonic current results

Hn	I _{eff} [A]	% of Limit	Limit [A]	Result
1	6.154			
2	2.563E-3			PASS
3	5.639E-3			PASS
4	2.477E-3			PASS
5	6.115E-3			PASS
6	2.773E-3			PASS
7	4.524E-3			PASS
8	2.260E-3			PASS
9	4.823E-3			PASS
10	2.255E-3			PASS
11	5.102E-3			PASS
12	2.238E-3			PASS
13	2.437E-3			PASS
14	2.083E-3			PASS
15	3.496E-3			PASS
16	2.038E-3			PASS
17	2.531E-3			PASS
18	2.017E-3			PASS
19	3.087E-3			PASS
20	2.084E-3			PASS
21	2.771E-3			PASS
22	2.036E-3			PASS
23	2.152E-3			PASS
24	2.326E-3			PASS
25	2.635E-3			PASS
26	2.437E-3			PASS
27	3.072E-3			PASS
28	2.292E-3			PASS
29	2.925E-3			PASS
30	2.159E-3			PASS
31	2.347E-3			PASS
32	1.858E-3			PASS
33	2.576E-3			PASS
34	2.076E-3			PASS
35	2.907E-3			PASS
36	2.252E-3			PASS
37	3.245E-3			PASS
38	2.650E-3			PASS
39	4.546E-3			PASS
40	2.695E-3			PASS

Test N.2

FLICKER – FLUTTUAZIONI DI TENSIONE

Reference standard

EN 61000-3-3

List of reference equipment

- Stabilized Power Supply Ametek mod. MX30 (Inv. 2781967)
- Flicker reference Impedance EM Test mod. AIF503N32 (Inv. 2781970)
- Software EM Test NET.control 2.1.5

Measurement Uncertainty

Expanded uncertainty: 5,6% of reading
Coverage probability: 95 %
Coverage factor: 2,0

Number of samples under test

1

Test Conditions	Required	Measured
Ambient Temperature	(15 ÷ 35) °C	(22 ± 2) °C
Ambient Relative Humidity	(25 ÷ 75) %rH	(55 ± 10) %rH
Test Setup	EN 61000-3-3 par. 4	
Test Procedure	EN 61000-3-3 par. 6	
EUT Operating Mode(s)	#1	
Acceptance Criteria	Limits are indicated in EN 61000-3-3 par. 5	

Test Results – Operating condition #1

Standard used: EN/IEC 61000-3-3 Flicker
 Short time (Pst): 10 min
 Observation time: 10 min (1 Flicker measurement)
 Modality of test: Heating element On at 30°C

Flicker Measurements					
	P _{It}	Max P _{st}	Max D _c	Max D _{max}	Max T _{max}
Line 1:	N.A.	0,028	0,013	0,067	0
Limits:	<i>No Limit</i>	1	3,3	4	0,5
Results:		PASS	PASS	PASS	PASS

Test Results – Operating condition #2

Standard used: EN/IEC 61000-3-3 Flicker
 Short time (Pst): 10 min
 Observation time: 10 min (1 Flicker measurement)
 Modality of test: 1 manual start and 1 manual stop

Flicker Measurements					
	P _{It}	Max P _{st}	Max D _c	Max D _{max}	Max T _{max}
Line 1:	N.A.	0,258	1,214	1,257	0
Limits:	<i>No Limit</i>	1	3,3	4	0,5
Results:		PASS	PASS	PASS	PASS

Test N.3

CONDUCTED EMISSION – EMISSIONE CONDOTTA

Reference standard

EN 55014-1

List of reference equipment

- EMI Test Receiver R&S mod. ESR 3 (Inv. 2782868)
- LISN R&S mod. ENV432 (Inv. 9002822)

Measurement Uncertainty

Expanded uncertainty (9kHz – 30MHz): 3,3 dB

Coverage probability: 95 %

Coverage factor: 2,0

Number of samples under test

1

Test Conditions

Required

Measured

Ambient Temperature

(15 ÷ 35) °C

(22 ± 2) °C

Ambient Relative Humidity

(25 ÷ 75) %rH

(49 ± 10) %rH

Test Setup

EN 55014-1 par. 5.2

Test Procedure

EN 55014-1 par. 6

EUT Operating Mode(s)

#1

Acceptance Criteria

Class B EUT: limits are indicated in EN 55014-1


Test Result

EUT Operating Mode(s) #1

AC Mains Power Neutral

Measure time Scan time 2 sec. (TD scan)

Detector Quasi-Peak trace (yellow trace); Average trace (green trace)




Test Result

EUT Operating Mode(s) #1

AC Mains Power Phase

Measure time Scan time 2 sec. (TD scan)

Detector Quasi-Peak trace (yellow trace); Average trace (green trace)



Test N.4

POWER DISTURBANCE – POTENZA DI DISTURBO

Reference Standard

EN 55014-1

List of reference equipment

- Semianechoic Chamber ETS-Lindgren mod.FACT3 (Inv. 2926063)
- EMI Test Receiver R&S mod. ESW 44 (Inv. 2782867)
- Schwarzbeck Messelektronik Clamp mod. MDS21 (Inv. 9001930)
- Huber&Suhner 6dB Attenuator N-N mod. 6806.17.A (Inv. 2782424)
- Software R&S EMC32 V.10.60.10

Measurement Uncertainty

Expanded uncertainty: 4,4 dB
Coverage probability: 95 %
Coverage factor: 2,0

Number of samples under test

1

Test Conditions

Required

Measured

Ambient Temperature

(15 ÷ 35) °C

(20 ± 2) °C

Ambient Relative Humidity

(25 ÷ 75) %rH

(46 ± 10) %rH

Test Setup

EN 55014-1 par. 5.2

Test Procedure

EN 55014-1 par. A.4.2

EUT Operating Mode(s)

#1

Acceptance Criteria

Limits according to Table 2 of EN 55014-1


Test Results

EUT Operating Mode(s) #1

Measure time Scan time 100 msec.

Detector Peak trace (blue trace); Average trace (green trace)

Full Spectrum



Test N.5

ELECTROSTATIC DISCHARGE – SCARICHE ELETTROSTATICHE

Reference Standard

EN 61000-4-2

List of reference equipment

- ESD Simulator EM Test mod. DITO (Inv. 9015313) with discharge Impedance EM Test type 330Ω / 150pF

Measurement Uncertainty

Expanded uncertainty: 10,8% of set voltage

Coverage probability: 95 %

Coverage factor: 2,0

Number of samples under test

1

Test Conditions

Required

Measured

Ambient Temperature

(15 ÷ 35) °C

(22 ± 2) °C

Ambient Relative Humidity

(25 ÷ 75) %rH

(50 ± 10) %rH

Test Setup

EN 61000-4-2 par. 7

Test Procedure

EN 61000-4-2 par. 8

EUT Operating Mode(s)

#1

Acceptance Criteria

B (see COMPLIANCE CRITERIA FOR IMMUNITY TESTS)

Test Results

Discharge Points	Application mode	Level (kV)	Number of applications	Notes	Result Classification	Standard Requir.	Result
Point 1 Radiator some points	Contact Discharge	±4	10	No performance degradation	Crit. A	Crit. B	PASS
Point 2 Electronic module front side + display	Air Discharge	±8	10	No performance degradation	Crit. A	Crit. B	PASS
Point 3 Electronic module push buttons	Air Discharge	±8	10	No performance degradation	Crit. A	Crit. B	PASS
Point 4 Electronic module rear side	Air Discharge	±8	10	No performance degradation	Crit. A	Crit. B	PASS
Point 5 Electronic module lateral sides	Air Discharge	±8	10	No performance degradation	Crit. A	Crit. B	PASS
Point 6 Electronic module VCP	Contact Discharge	±4	10	No performance degradation	Crit. A	Crit. B	PASS


See next page for points of electrostatic discharge.



Contact Discharge points;  Air Discharge points.

Note: VCP (Vertical Coupling Plane)

PUNTI DI SCARICA ELETTROSTATICA / ELECTROSTATIC DISCHARGE POINTS



Point 1



Point 2




Point 3



Point 4



Point 4



Point 5

Test N.6

FAST TRANSIENTS - TRANSITORI VELOCI

Reference Standard

EN 61000-4-4

List of reference equipment

- Fast Transient/Burst Generator Em Test mod. UCS 500 N7.7 (Inv. 2782326)
- Three-phase Coupling/Decoupling Network Em Test mod. CNI 503B7.5 (Inv. 2782327)
- Software IEC.CONTROL version 5.3.1 (Inv. 2782380)

Measurement Uncertainty

Expanded uncertainty: 10,3% of set voltage
Coverage probability: 95 %
Coverage factor: 2,0

Number of samples under test

1

Test Conditions

Required

Measured

Ambient Temperature

(15 ÷ 35) °C

(21 ± 2) °C

Ambient Relative Humidity

(25 ÷ 75) %rH

(50 ± 10) %rH

Test Setup

EN 61000-4-4 par. 7

Test Procedure

EN 61000-4-4 par. 8

EUT Operating Mode(s)

#1

Acceptance Criteria

B (see COMPLIANCE CRITERIA FOR IMMUNITY TESTS)

Test Results

Tested Port	Coupling mode	Burst Characteristics		Test Duration (s)	Notes	Result Classification	Standard Requirement	Result
		Level (Kv)	Frequency (kHz)					
AC mains	L1	-1	5	120	No performance degradation	Crit. A	B	COMPLIANT
AC mains	L1	+1	5	120	No performance degradation	Crit. A	B	COMPLIANT
AC mains	N	-1	5	120	No performance degradation	Crit. A	B	COMPLIANT
AC mains	N	+1	5	120	No performance degradation	Crit. A	B	COMPLIANT
AC mains	PE	-1	5	120	No performance degradation	Crit. A	B	COMPLIANT
AC mains	PE	+1	5	120	No performance degradation	Crit. A	B	COMPLIANT
AC mains	L1-N-PE	-1	5	120	No performance degradation	Crit. A	B	COMPLIANT
AC mains	L1-N-PE	+1	5	120	No performance degradation	Crit. A	B	COMPLIANT

Test N.7

SURGE - IMPULSI

Reference Standard

EN 61000-4-5

List of reference equipment

- Surge/Burst Generator Em Test mod. UCS 500 N7.7 (Inv. 2782326)
- Three-phase Coupling/Decoupling Network Em Test mod. CNI 503B7.5 (Inv. 2782327)
- Software IEC.CONTROL version 5.3.1 (Inv. 2782380)

Measurement Uncertainty

Expanded uncertainty: 10,3% of set voltage
Coverage probability: 95 %
Coverage factor: 2,0

Number of samples under test

1

Test Conditions

Required

Measured

Ambient Temperature

(15 ÷ 35) °C

(21 ± 2) °C

Ambient Relative Humidity

(25 ÷ 75) %rH

(50 ± 10) %rH

Test Setup

EN 61000-4-5 par. 7

Test Procedure

EN 61000-4-5 par. 8

EUT Operating Mode(s)

#1

Acceptance Criteria

B (see COMPLIANCE CRITERIA FOR IMMUNITY TESTS)

Test Results

Tested Port	Coupling mode (coupling impedance)	Surge Characteristics			Events	Result Classification	Standard Requirement	Notes
		Level (kV)	Phase (°)	Repetition (min)				
AC mains	L-N (2Ω)	+1	90°	1	5	Crit. A	B	No performance degradation
		-1	270°		5			
AC mains	L-PE (12Ω)	+2	90°	1	5	Crit. A	B	No performance degradation
		-2	270°		5			
AC mains	N-PE (12Ω)	+2	90°	1	5	Crit. A	B	No performance degradation
		-2	270°		5			

Test N.8

INJECTED CURRENTS - CORRENTI INIETTATE

Reference Standard

EN 61000-4-6

List of reference equipment

- RF Generator Marconi Instruments mod. Signal 2023 (Inv. 9001705)
- RF Amplifier Amplifier Research mod. 25A250A (Inv. 9001706)
- Coupling/Decoupling Network EM Test mod. M3 (Inv. 2782330)
- 6dB RF Attenuator EM Test mod.ATT6/75 (Inv. 2782376)

Measurement Uncertainty

Expanded uncertainty: 3,3 dB
Coverage probability: 95 %
Coverage factor: 2,0

Number of samples under test

1

Test Conditions

Required

Measured

Ambient Temperature

(15 ÷ 35) °C

(22 ± 2) °C

Ambient Relative Humidity

(25 ÷ 75) %rH

(48 ± 10) %rH

Test Setup

EN 61000-4-6 par. 7

Test Procedure

EN 61000-4-6 par. 8

EUT Operating Mode(s)

#1

Acceptance Criteria

A (see COMPLIANCE CRITERIA FOR IMMUNITY TESTS)

Test Results

Tested Port	Test frequency (MHz)	Disturbance Characteristics			Coupling device	Result Classification	Notes
		Level (V)	Dwell time (s)	Modulation Freq.			
AC Mains	0,15 - 230	3	3	1kHz 80%AM	CDN M3	PASS Crit. A	No performance degradation

Test N.9

VOLTAGE DIPS – BUCHI DI TENSIONE

Reference Standard

EN 61000-4-11

List of reference equipment

- Stabilized Power Supply Ametek mod. MX30 (Inv. 2781967)
- Software California Instruments MXGUI Version 2.2.0.9

Measurement Uncertainty

Expanded uncertainty: 3,8% of set voltage

Coverage probability: 95 %

Coverage factor: 2,0

Number of samples under test

1

Test Conditions

Required

Measured

Ambient Temperature

(15 ÷ 35) °C

(21 ± 2) °C

Ambient Relative Humidity

(25 ÷ 75) %rH

(47 ± 10) %rH

Test Setup

EN 61000-4-11 par. 7

Test Procedure

EN 61000-4-11 par. 8

EUT Operating Mode(s)

#1

Acceptance Criteria

C (see COMPLIANCE CRITERIA FOR IMMUNITY TESTS)

Test Results

Tested Port	Dip to %	Ts (Cycles)	Frequency	Result Classification	Standard Requirement	Notes
AC Mains	0%	0	50Hz	PASS Crit. A	C	No performance degradation
AC Mains	40%	10	50Hz	PASS Crit. A	C	No performance degradation
AC Mains	70%	25	50Hz	PASS Crit. A	C	No performance degradation

END OF TEST REPORT